

Request for Medium Pressure Gas

Chapter 13, Appendix B of the California Mechanical Code and Chapter 12 of the California Plumbing Code regulate medium pressure gas installations.

Exposed piping and piping on the roof may be threaded pipe. Concealing of medium pressure gas piping shall be avoided, but if approved, joints shall be welded. **The necessary regulators shall be readily accessible with permanent ladders, catwalks, working platforms and lights as required for inspection and servicing.**

Gas valves shall be approved for the pressure supplied.

Medium pressure gas lines shall be tested at **sixty (60) psi** for a period of **twenty-four (24) hours** with an approved graph.

Submit to the Building Department two (2) isometric or figure drawings of the gas piping indicating location of the piping, appliances, regulators, including relief piping and gas meter in relation to the building walls and lot line for approval prior to doing the work.

Building Address: _____ Suite No. : _____

Owner: _____

Plumb. /Mech. Contractor: _____ Phone No. : _____

Address: _____ License No. : _____

Both the City of Sacramento Building Division and PG&E have approved the request for medium pressure gas service at the above address.

The requested demand is _____ BTUH

The pressure requested is _____ psi.

Authorized Signature Printed Name and Title PG&E Date

City of Sacramento Date
Plan Reviewer Signature