

COMMON VIOLATIONS FOR BUSINESS OWNERS

This list is meant as a guide of common violations. There may be other violations found at your business

1. Service fire extinguishers annually and perform monthly checks (Title 19 Division 1, 574.1)
2. Ensure Fire Extinguishers are hung or in cabinet per code (CFC 906.7)
3. Fire alarm and fire sprinkler systems shall be maintained in proper working condition. (CFC 901.7)
4. Ensure required testing of fire sprinkler, fire alarm, fire pump, fire hydrant and standpipe system has been performed by licensed contractor (CFC 108.3)
5. Make sure fire lanes are clearly marked. NO PARKING – FIRE LANE (CFC 503)
6. Shall service kitchen hood extinguishing system every 6 months. (CFC 607.3.3)
7. Kitchen hood to be professionally cleaned by a qualified individual. (CFC 607.3.3, ANSI/IKECA C10)
8. Remove all extension cords run as permanent wiring. (CFC 604.5)
9. Remove all power strips connected together (daisy chained) (CFC 604.4.2)
10. Cover open electrical outlets and wiring (CFC 604.6)
11. Remove multi plug adapters. (CFC 604.4)
12. Portable electric heaters must be connected directly to a permanent outlet (CFC 604.10.2)
13. Ensure all electrical outlets are in good working order and have appropriate cover plate (CFC 604.6)
14. Ensure all exiting remain unblocked and open easily (CFC 1031.2 & 1010.1.9)
15. Remove all pin and bolt locks on required exit doors (CFC 1010.1.9.5)
16. Remove door stops from fire rated doors (CFC 705.2)
17. Secure all compressed gas cylinders. (CFC 5303.5.3)
18. Storage maintained 18" below height of fire sprinkler heads, 24" from ceiling (non-sprinklered) (CFC 315.3.1)
19. No storage in mechanical or electrical rooms. (CFC 315.3.3)
20. Area in front of electrical panels shall be clear for 36" (CFC 604.3)
21. Clear area around water heaters 36" (CFC 315.3)
22. Repair any holes in fire rated construction (CFC 703.1)
23. Ensure all ceiling tiles are intact and in place (CFC 703.1)
24. Repair or replace any non-operational/damaged emergency and exit lights. (CFC 1008.2 & 1013.3)
25. Building address must be clearly legible

Business Name: _____

Address: _____

Phone number: _____

Manager Name: _____

Phone number: _____

Email: _____

Building owner name: _____

Building owner phone number: _____

Billing address: _____