

**JOB SITE INSPECTION RECORD MUST BE POSTED ON JOB SITE**  
**THIS PERMIT SHALL EXPIRE IF WORK IS NOT COMMENCED WITHIN 180 DAYS OF ISSUANCE**

1. Do not cover walls or ceiling or bury piping until all of the following checked items are signed off.
2. An all-weather (paved) emergency access roadway and operating fire hydrants shall be provided prior to any combustible storage or construction on site.

☑	Code	Inspection Type	1st Inspection		2nd Inspection		Additional Inspection	
	100	Fire Alarm System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	100.1	Battery Test	Pass	FP-15	Pass	FP-15	Pass	FP-15
	101	Fire Sprinkler Monitoring	Pass	FP-15	Pass	FP-15	Pass	FP-15
	200.1	O/H Visual	Pass	FP-15	Pass	FP-15	Pass	FP-15
	200.2	O/H Hydro	Pass	FP-15	Pass	FP-15	Pass	FP-15
	201.1	UG Visual	Pass	FP-15	Pass	FP-15	Pass	FP-15
	201.2	UG Hydro	Pass	FP-15	Pass	FP-15	Pass	FP-15
	201.3	UG Flush	Pass	FP-15	Pass	FP-15	Pass	FP-15
	202	Fire Pump	Pass	FP-15	Pass	FP-15	Pass	FP-15
	203	Pre-Action System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	204	Standpipe System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	205	Deluge System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	207	Fire Extinguishers	Pass	FP-15	Pass	FP-15	Pass	FP-15
	301	FM-200	Pass	FP-15	Pass	FP-15	Pass	FP-15
	302	CO2 System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	304	Dry Chem System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	305	Wet Chem system	Pass	FP-15	Pass	FP-15	Pass	FP-15
	307	Paint Booth	Pass	FP-15	Pass	FP-15	Pass	FP-15
	309	Med Gas system	Pass	FP-15	Pass	FP-15	Pass	FP-15
	310	Smoke Removal	Pass	FP-15	Pass	FP-15	Pass	FP-15
	311	Kitchen Hood System	Pass	FP-15	Pass	FP-15	Pass	FP-15
	400	Racking	Pass	FP-15	Pass	FP-15	Pass	FP-15
	401	Propane Cylinder Racks	Pass	FP-15	Pass	FP-15	Pass	FP-15
	402	High Piled Storage Racks	Pass	FP-15	Pass	FP-15	Pass	FP-15
	500	Cell Tower	Pass	FP-15	Pass	FP-15	Pass	FP-15
	501	Photovoltaic (PV)	Pass	FP-15	Pass	FP-15	Pass	FP-15
	600	Tank Install	Pass	FP-15	Pass	FP-15	Pass	FP-15
	601	Flammable Liquids	Pass	FP-15	Pass	FP-15	Pass	FP-15
	602	Hazardous Materials	Pass	FP-15	Pass	FP-15	Pass	FP-15
	701	Knox Box	Pass	FP-15	Pass	FP-15	Pass	FP-15
	701.1	Access	Pass	FP-15	Pass	FP-15	Pass	FP-15
	900	Other Systems	Pass	FP-15	Pass	FP-15	Pass	FP-15
194		<b>FIRE FINAL</b>			/	/	<b>Call sign:</b>	

**DO NOT OCCUPY BUILDING UNTIL ALL OF THE INSPECTIONS SELECTED ABOVE HAVE BEEN APPROVED  
AND A CERTIFICATE OF OCCUPANCY HAS BEEN ISSUED BY THE BUILDING DEPARTMENT.**