

## DRAINAGE PUMP STATION DATA

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
001		4-270	67.4	249.6			55B 97R		2100 Block of Front St.
001A		3-270	62.4	187.2					Front St. 2100 Block Rear of "U" St.
002		4-350 2-350 1-350 1-350 1-200 1-200 1-110	46.4 61.9 69.6 38.6 40.1 30.9 15.5	504.1					3530 Riverside Blvd.
002A		3-500 3-300	77.36 46.4	371.3					3530 Riverside Blvd.
004	240	1-25	6.7	6.7	Undefined <sup>2</sup>		12-52	100	Curtis Park Sump; to combined system
005	480	2-15	8.0	16.0	96	0.17/0.083	02-50	88	5542 Fruitridge Rd. and 48 <sup>th</sup> St; discharges to Sump 96
007	240 480	2-30	5.6	11.2	5	2.24/1.12 <sup>3</sup>	10-96	100	1790 Expo Parkway @R/R Bridge
008	240 480	3-50	16.3	48.9	214	0.23/0.15	05-51	81	5975 64 <sup>th</sup> St.
010	240 480	2-100; 2-60	31.2; 20.1	102.6	702	0.15/0.10	12-53	100	5105 Sandburg
014	240 480	3-40 2-10	16.0 4.0	56	488	0.11/0.08 <sup>5</sup>	08-99	10 <sup>4</sup>	1 Mile North off Del Paso Rd.
015	240 480	4-60 1-10	25.1 5.0	105.4	488	0.21/0.16 <sup>5</sup>	Aug.	10 <sup>4</sup>	
016	240 480	4-30 1-10	13.8 3.1	58.3	742	0.08/0.06 <sup>5</sup>	08-99	10 <sup>4</sup>	3330 Airport Rd.
017	240 480	4-60 1-15	22.3 5.0	94.2	743	0.13/0.10 <sup>5</sup>	10-99	10 <sup>4</sup>	San Juan Rd. & Whittier Way

<sup>1</sup>All pumps/less 1 large pump

<sup>2</sup> Within combined system

<sup>3</sup> underpass pump station @ Exposition Blvd.

<sup>4</sup> Based on 1999

<sup>5</sup>Upstream Detention

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
019	240 480	2-30	11.1	22.2	88	0.25/0.13	11-54	90	4500 52 <sup>nd</sup> Ave.
020	240 280	3-75 1-20	33.42 5	105.2	272	.39/.26	08-97	80	So. of Truxel, West of I-80
022	240 480	2-100 1-25	40.1 11.4	91.3	379	0.24/0.14	12-54	100	Gate next to 6796 Golf View Dr.
023	240 480	2-25	9.6	19.2			11-98		Executive Airport behind Corp yard
024	240 480	2-50	33.4	66.8	396	0.17/.08	9-55	100	6555 Freeport Blvd. @ Bing Malone G.C.
025	240 480	1-30	11.1	11.1	63	.17/.17	12-54	95	5730 24 <sup>th</sup> Street
026	240 480	4-50	27.8	111.2	1010	0.11/0.08	11-55	82	5711 Freeport Blvd; to Sump 104
027	240 480	2-15	7.1	14.2	54	0.26/0.13	01-56	97	6420 South Land Park; to Sump 28
028	2300; 480	3-350; 1-150; 1-75; 1-60; 1-25 1-100	89.1; 23.4; 20.1; 16.7; 0.67 23.4	351.6	2853 <sup>6</sup>	0.12/0.09	11-57	60	7788 Freeport Blvd; discharges into Sac River
030	240 480	2-7.5	7.1	14.2	32	0.46/0.23	08-58	90	6704 South Land Park Dr; discharges into Sump 28
031	240 480	4-350 1-15	50 2.5	202.5	865	0.23/0.18	04-59	Recon- structed 2003	6441 Elvas Ave. @ 65 <sup>th</sup> St.
033	240 480	3-75 1-25	36.2 7.8	116.4	718	0.16/0.11	02-58	70	2190 Meadowview Rd.
034		3-350 1-40	87.3 9.0	270.9	699+718= 1417 <sup>7</sup>	0.19/0.13	02-58 96R	40	7851 Freeport Blvd.
035	480	3-40	15	45	30	1.5/1.0	99		7500 Block of Myrtle Ave

<sup>1</sup>All pumps/less 1 large pump  
<sup>6</sup>Contributing Sumps - 65, 94, 30, 100, 27, 47, 22, 108, 35, 24, 54, 25, 138, 46, 71, 142, 39, 28  
<sup>7</sup>33 discharge to 34

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
037	240 480	3-75	15.6	46.8	151	0.31/0.21	12-58	97	4800 Power Inn Rd.
038	240 480	1-20 1-25	7.8 7.8	15.6	6	2.60/1.30 <sup>8</sup>	01-59	49	J St. Subway
039	240 480	2-15	10.0	20.0	77	0.26/0.13	12-58	97	6792 South Land Park Dr.
041	240 480	2-25	4.5	9	67	0.13/0.07	1995	100	1000 Rio Lane
043	240 480	3-100 1-15	25.8 2	79.4	511	0.16/0.10	Acq. 1959	70	4801 Power Inn Rd.
044	240 480	2-40	20.1	40.2	94	0.43/0.21	Acq. 1959	94	6220 Sun River Dr.
046	240 280	2-30 1-3	17.8 1.8	37.4	78	0.47/0.25	12-59	85	7271 24 <sup>th</sup> Street
047	240 480	2-20	9.8	19.6	57	0.34/0.17	12-59	100	6610 13 <sup>th</sup> Street
050	240 480	2-20	12.8	25.6	83	0.30/0.15	05-60	94	6809 75 <sup>th</sup> Street
051	240 480	2-30	13.6	27.2	91	0.30/0.15	11-60	100	6161 Power Inn Road
052	240 480	3-200; 1-50	32.5; 9.4	106.9	271	0.39/0.27	12-60	100	215 P Street
054	240 480	3-50`	16.3	48.9	240	0.20/0.13	09-61	69	7201 25 <sup>th</sup> St.; discharges to Sump 28
056	240 480	1-7.5	3	3	5	0.6/0.0	01-61	100	980 Seamas Ave
058	240 480	2-100 1-30	17 4.7	38.7	65	0.59/0.33	Acq. 07-61	100	1156 Azusa Street
063	240 480	4-100	17.8	71.2	469	0.15/0.11	03-62	90	725 ½ Clipper Way
065	240 480	3-60	20	60	294	0.20/0.14	02-62	97	1145 Silverlake Way
066	240 480	3-125; 1-20	65.3 6.7	202.6	491	0.41/0.28	02-63	94	Florin-Perkins Rd.
067	240 480	3-150; 1-30	52.6 10.0	167.8	883	0.19/0.13	10-63	74	7756 Center Parkway
068	240 480	2-100 1-40 1-50	31.2 6.7 14.5	83.6	304	0.27/0.17	10-63 Up-'97	82	Franklin Blvd.

<sup>1</sup>All pumps/less 1 large pump

<sup>8</sup>underpass pump

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
069	240 480	3-150; 1-30	58.2; 10.0	184.6	1038	0.18/0.12	09-63	78	8241 Center Parkway
070		2-100 1-20	21.6 0.4	43.6	213	0.20/0.10	01-64	100	6482 Surfside Way
071	240 480	3-25	13.4	40.2	228	0.18/0.12	01-64	97	7340 Willow Lake Way
073	240 480	2-15	2.3	4.6	2	2.3/1.15	01-64	100	4 <sup>th</sup> & J Parking Garage - 5 <sup>th</sup> St. underpass
077	240 480	2-6	2.2	4.4			01-97		1753 42 <sup>nd</sup> Street underpass??
083	240 480	1-10	2.3	2.3	8	0.29/0.0	01-65	100	793 Del Paso Blvd. & W. P. Subway
089	240 480	3-250; 1-50	75.8 13.4	240.8	1345	0.18/0.12	11-65	30	East of Beach Lake Road
090	2300	1-450 1-100	110.3 22.3	over-flow	from	Morrison Creek	12-65		8685 Freeport Blvd.
090A	2300	1-450	110.3	132.6					So. of Sump 90 on Snod Grass Slough
091	240 480	3-125	41.9	125.7	482	0.26/0.17	05-65	100	7929 La Riveria and Howe Park
092	2300	2-300 1-75	75.8 20.1	171.7	1138	0.15/0.08	Take over 05-65	100	8505 La Riveria Drive
094	240 480	2-25	7.8	15.6	62	0.25/0.13	06-66	98	7005 Reichmuth Way
095	240 480	3-250 1-25	69.5 4.7	213.2	489	0.43/0.29	10-66	100	184 Cadillac Dr.
096	240 480	3-250 2-125 1-20	80.2 40.1 4.5	325.3	1072	0.30/0.23	11-66	60	6525 65 <sup>th</sup> Street
097	240 480	3-125 1-20	40.1 4.9	125.2	377	0.33/0.23	10-66	57	6343 24 <sup>th</sup> Street
098	240 480	3-125; 1-25;	59.0; 10.0	187 cfs	627	0.30/0.20	09-66	83	3053 Northstead Dr.
099	240 480	3-300; 1-25	64.6; 4.2	198.1	386	0.51/0.35	11-66	100	3401 Lanatt and Elvas Avenue

<sup>1</sup>All pumps/less 1 large pump

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
100	240	1-7.5	3.6		1.1 <sup>9</sup>		09-67	100	1144 Silver Lake Drive
101	4160; 4160; 480	2-350; 1-150; 1-25	73.5; 32.1; 4.8	183.9	371	0.52/0.31	11-68	97	5701Elvas Ave
102	240 480	2-200 1-25	45.1 4.5	94.7	412	0.23/0.12	11-68	60	300 Bowman Street
103	240 480	2-75 1-7.5	40.1 4.1	84.3	269	0.31/0.16	02-68	60	3230 Los Altos
104	4160	4-700 2-350 1-50	111.4 53.5 6.3	558.9	872	0.64/0.51	01-68	97	5610 So. Land Park Dr.
108	240 480	1-25 1-40	13.9 33.4	47.3	159	0.3/0.09	04-76	85	2075 63 <sup>rd</sup> Ave
109	240 480	2-60 1-50	20.2 5.8	46	110	0.42/0.23	02-68	100	117 Breckenwood Way
110	240 480	1-7.5	spill	structure	237 <u>overflow</u> for Greehaven		10-68	100	Havenside drive and Sail Court
111	240 480	3-200; 1-25	67.5; 5.1	207.6	452	0.46/0.31	11-68	97	Richards Blvd and 5 <sup>th</sup> Street
112	480	3-15	7.4	22.2	48	0.46/0.30	03-70	100	Lake Greenhaven sump; discharges into Sump 63
113	240 480	1-7.5	2.2	2.2	3.2	0.68 <sup>10</sup>	Taken over '68	100	6800 Folsom Blvd.
114	240 480	1-5	1.3	1.3	45	0.04/0.00	02-71	100	401 J Street
115	240 480	2-100 1-25	32.3 4.5	69.1	153	0.45/0.24	06-71	85	4100 Brookfield Dr.
116	240 480	3-75 1-5	22.3 1.3	68.2	232	0.29/0.20	06-71	100	5890 88 <sup>th</sup> Avenue
117	240 480	1-40; 1-5	34.8; 1.6	36.4	206	0.18/0.00	10-77	60	1820 Bell Ave
128	240 480	4-200; 1-30	37.9; 7.6	159.2	641	0.25/0.19	11-74	40	3917 Mack Road

<sup>1</sup>All pumps/less 1 large pump

<sup>9</sup>lift only discharges to 28

<sup>10</sup>pumps to 101

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
129	240 480	3-400; 2-300; 1-50	133.7; 81.3; 8.7	572.4	1431	0.4/0.31	01-76	100	3308 San Juan @ I-80
130	240 480	3-200; 1-10	71.1; 4.0	217.3	503	0.43/0.29	'71-'75	49	2550 W. El Camino
132	4160	1-1200 5-1000 2-300	189.4 189.4 60.2	1256.8	2057	0.61/0.52	10-77	97	7526 Pocket Road
138	240 480	3-100 1-40	13.4 11.1	51.3	196	0.26/0.19	01-79	60	7531 Mapple Tree Way
139	240 480	3-60 1-25	20.1 6.0	66.3	216	0.31/0.21	08-79	82	8054 Torrente Dr.
140	240 480	3-250; 1-75	59.7; 4.5	178.2	462	0.39/0.26	09-81	87	140 Pinedale Ave..
141		3-200 1-50	60.9 13.4	196.1	408	0.48/.33			929 Elmeridge Wy., near Maple Grove & Turnstone
142	240 480	3-50; 1-30	13.5; 9	49.5	107	0.46/0.33	02-84	100	7455 Greenhaven Drive
144	240 480	3-250; 1-60	80.2 19.2	262.4	525	0.50/0.35	09-83	12	4101 May Street, north side of I-80
147	240 480	1-25	13.6	13.7	40	0.35/0.00	12-84	87	6260 Dias Ave.
148	240 480	3-75 7.5	30.1 2.2	92.5	163	0.57/0.38	6-85	70	8300 Elder Creek Rd.
149		2-10	2.8	5.6	<sup>11</sup>		05-86	100	1201 No. "A" Street
151	240 480	1-250 1-125 1-100 1-20 2-300	80.2 66.4 35.6 5.8 80.2	348.4	1001	0.35/0.27 <sup>12</sup>	11-97	80	600 Leisure Lane
152	4160 480	2-700 3-300 1-50	168.9 66.4 11.6	548.6	1598	0.34/0.24	11-67	100	Cal Expo Parking Lot "D"
153	240 480	2-150; 1-25	35.2; 4.9	75.3	242	0.31/0.17	06-68	100	2301 Colfax

<sup>1</sup>All pumps/less 1 large pump

<sup>11</sup>pumps to 111

<sup>12</sup>upstream detention

Sump No.	Voltage	HP	Pump (cfs)	Pump Station (cfs)	Area (acres)	cfs/acre <sup>1</sup>	Built	% Built (as of '92)	Location
154	240 480	3-125; 1-15	42.3; 4.5	131.4	651	0.20/0.14	06-67	85	77 Arcade Blvd
155	240 480	1-125; 1-125; 1-60; 1-50; 1-7.5	24.3; 23.6 50.2 45.1 2.5	145.6	128 1	1.14/0.81	12-57	49	6201 Camellia Avenue
157	240 480	2-500; 4-400; 1-50	153.5; 111.4; 17.8	770.4	2271	0.34/0.27	12-57	40	#1 Morrison Street
158	240 480	2-150	46.8	93.6	463	0.20/0.10	01-58	23	306 Fairbanks Ave.
159	240 480	1-150 1-100 1-15	38.9 19.2 2.9	94.4	585	0.16/0.10	06/68	60	813 Arcade Blvd.
160	diesel driven	2-715 2-420	124.3 63.5	376.6	400	0.94/0.63	99	30	S. of Garden Highway
200	240 480	1-30	8.0				04-97		8151 Bruceville Rd.
201	240 480	1-30	5.6	5.6	<sup>13</sup>				Consumnes River Blvd.
202	240 480	1-30	8.0	8.0	<sup>13</sup>				4805 Tangerine Ave.
203	240 480	1-30	8.0	8.0	<sup>13</sup>				8201 Franklin Blvd.

<sup>1</sup>All pumps/less 1 large pump

<sup>13</sup>storm relief pump no area defined