



**NOTES:**

1. APPROVED BACKFLOW PREVENTION ASSEMBLIES SHALL BE TESTED IMMEDIATELY AFTER THEY ARE INSTALLED, RELOCATED OR REPAIRED AND NOT PLACED IN SERVICE UNLESS THEY ARE FUNCTIONING AS REQUIRED.
2. TESTING OF BACKFLOW PREVENTION ASSEMBLIES SHALL BE PERFORMED BY CERTIFIED BACKFLOW PREVENTION ASSEMBLY TESTERS.
3. CURRENT LISTS OF APPROVED BACKFLOW ASSEMBLIES AND CERTIFIED TESTERS ARE AVAILABLE AT THE DEPARTMENT OF UTILITIES CUSTOMER SERVICE OFFICE, 1395 35TH AVENUE.
4. THE APPROVED BACKFLOW ASSEMBLY SHALL PASS THE REQUIRED TEST PRIOR TO FILLING THE NEW WATER MAIN.

| REV. | DATE | DESCRIPTION |
|------|------|-------------|
| △    |      |             |
| △    |      |             |
| △    |      |             |

**CITY OF SACRAMENTO  
DEPARTMENT OF UTILITIES**

**TYP. CONNECTIONS FOR INITIAL  
FILING OF NEW WATER MAIN**

APPR'D BY: *DDBT* NO SCALE  
DATE: MAY 2007 DWG. NO. **W - 107**