



NOTES:

1. "AIR GAP SEPARATION" MEANS A PHYSICAL SEPARATION BETWEEN THE DISCHARGE END OF A POTABLE WATER SUPPLY PIPELINE AND AN OPEN OR NON-PRESSURE RECEIVING TANK.
2. AN "APPROVED AIR GAP SEPARATION" SHALL BE AT LEAST TWICE THE DIAMETER OF THE SUPPLY PIPE MEASURED VERTICALLY ABOVE THE OVERFLOW RIM OF THE RECEIVING TANK. IN NO CASE SHALL THE AIR GAP BE LESS THAN ONE INCH.

REV.	DATE	DESCRIPTION
△		
△		
△		

**CITY OF SACRAMENTO
DEPARTMENT OF UTILITIES**

**REQUIREMENTS FOR FIRE HYDRANT
USE PERMITS WATER TRUCKS**

APPR'D BY: DOB NO SCALE
DATE: MAY 2007 DWG. NO. **W - 203**