



GENERAL NOTES

1. WATER SERVICE PIPE SHALL BE 1-INCH IN DIAMETER UP TO ABOVE GROUND TEE.
2. WHENEVER COPPER WATER SERVICE PIPE IS IN DIRECT CONTACT WITH CONCRETE, THE CONTRACTOR SHALL WRAP COPPER PIPE IN 35 MIL POLYKIN OR EQUAL, OR PLACE IN CASING.
3. WATER SERVICE PIPE MAY BE PLACED IN AN EXCAVATED TRENCH AND BACKFILLED, OR DIRECTIONALLY DRILLED.
4. PIPE ALIGNMENT SHALL NOT PASS UNDER ANY STRUCTURE.
5. WATER SERVICES AND THEIR INSTALLATION SHALL MEET APPLICABLE REQUIREMENTS OF SECTION 10 THRU 38 OF THESE SPECIFICATIONS.
6. TO TRANSITION FROM GALVANIZED PIPE TO COPPER PIPE, PLACE A BRASS UNION W/BRASS GATE VALVE BETWEEN GALVANIZED PIPE AND COPPER PIPE.

HOSE BIBB CONNECTION

REV.	DATE	DESCRIPTION
1		

R:\Utilstods\City_Std_Details\Water_Uilities\W-406