



DRAINAGE INLET WITH TRAP AND SUMP (TYPE II)

FOR COLLECTION AND DISCHARGE INTO COMBINATION SEWER

SCALE: 3/4"=1'-0"

NOTE:

1. MINIMUM WALL THICKNESS IS 6 INCHES FOR CAST-IN-PLACE CONCRETE.
2. REINFORCE CAST-IN-PLACE CONCRETE WALLS WITH #4 BARS AT 12"O.C. EACH WAY WITH 2" MIN. COVER FROM INSIDE FACE

FIGURE 1