

INFORMATION YOU SHOULD KNOW ABOUT WATER

This Consumer Confidence Report (CCR) is a summary of results of tests conducted to detect contaminants in your drinking water. It has been provided to educate you, our customer, about the quality of your drinking water. Many tests were conducted and only those constituents detected are listed in this report.

The CCR includes a comparison of the detected chemicals in the City of Sacramento Department of Utilities' drinking water to the standards set by the State Department of Health Services (Department) and the United States Environmental Protection Agency (USEPA).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (1-800-426-4791).

YOUR WATER MEETS OR EXCEEDS ALL CURRENT FEDERAL AND STATE REQUIREMENTS

SPECIAL INFORMATION AVAILABLE

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

HELPFUL PHONE NUMBERS AND INFORMATION

The City of Sacramento Department of Utilities is dedicated to providing safe, reliable and environmentally sensitive water, drainage, sewer and flood control to our customers.

City of Sacramento Department of Utilities

(24 hours a day, 7 days a week)

311 or (916) 264-5011

www.cityofsacramento.org/utilities

USEPA Safe Drinking Water Hotline

(800) 426-4791

www.epa.gov/drink

The City Council holds public meetings most Tuesdays at 6 p.m. in the City Council Chambers at 915 I Street, Sacramento. You can access Council agendas at www.cityofsacramento.org/clerk.

本報告有關於您的飲用水的重要資料。請找人為您翻譯，或與能明白該報告的人交談。

Phúc trình này có các chi tiết quan trọng về nước uống của quý vị. Hãy nhờ người dịch cho quý vị, hoặc hỏi người nào hiểu rõ các chi tiết này.

Este informe contiene información importante sobre el agua que usted bebe. Pida a alguien que se lo traduzca o hable con alguien que lo entienda.

ລາຍງານນີ້ມີຂໍ້ມູນສຳຄັນກ່ຽວກັບນ້ຳປະປາຂອງທ່ານ. ຈົ່ງໃຫ້ຄົນອື່ນຮຽນຄວາມໃຫ້ທ່ານ, ຫລືໃຫ້ປຶກສາກັບຄົນໃດຄົນໜຶ່ງທີ່ເຂົ້າໃຈເລື່ອງ.

この報告書には私達の飲料水に関する重要な情報が記載されています。貴方のために翻訳してくれる人、あるいは内容を理解し説明してくれる人を見つけてください。

Tsab ntawv (report) no muaj cov kev qhia tseemceeb txog koj cov dej haus. Thov ib tus tibneeg pab txhais rau koj lossis nrog tej tus tibneeg uas totaub txog tsab ntawv no tham.

Ang report na ito ay naglalaman ng mahalagang impormasyon tungkol sa tubig na inyong iniinum. Magpatulong sa taong maaring magsalin, o makipag-usap sa taong nakakaunawa nito.

Данный рапорт содержит важную информацию о вашей питьевой воде. Переведите его или проконсультируйтесь с тем, кто его понимает.



CALL 916-264-5011
我們講中文 · Hablamos Español
Мы говорим по-русски · ພວກເຮົາເວົ້າພາສາລາວໄດ້
Peb hais lus Hmoob · Chúng tôi nói tiếng Việt

2010 WATER QUALITY REPORT

A Consumer Confidence Report for the Citizens of Sacramento

Congratulations!
Your water meets or exceeds all federal and state drinking water standards



CITY OF SACRAMENTO
DEPARTMENT OF UTILITIES

TRADITION OF EXCELLENCE

Since its founding in 1849, the City of Sacramento has considered water quality of utmost importance. This Consumer Confidence Report is presented to enhance your understanding of where your water comes from and what it contains and to confirm that your drinking water continues to meet or exceed all state and federal drinking water standards.

The City of Sacramento Department of Utilities is committed to providing high quality, reliable, and environmentally sensitive water, sewer, drainage and solid waste services to the residents of Sacramento. In doing so, we work to conserve and preserve our water sources.

CALIFORNIA SOURCE WATER QUALITY

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, U.S. Environmental Protection Agency (USEPA) and the State

Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

SACRAMENTO'S WATER SOURCE ASSESSMENT

The City of Sacramento has two independent water sources. Our primary water source is river water from the American and Sacramento Rivers, which provide 84 percent of our water supply. Groundwater provides the remaining 16 percent. Assessments of potential contaminating activities for the City's Sacramento River and American River water sources were completed in December 2000 and April 2001. These reports indicated that both rivers are most vulnerable to contaminants from recreational activities and that the Sacramento River is also most susceptible to agricultural contaminants.

An assessment of the City's groundwater wells was completed in December 2002. Two wells are considered most vulnerable to automotive services and have an associated contaminant detected in the water that the wells produce. However, the City's drinking water meets all current state and federal drinking water standards. In addition, due to the proximity to potential contaminant sources, the wells north of the American River are considered most vulnerable to sewage collection systems, leaking underground storage tanks, known contaminant plumes, agricultural drainage, gas stations, dry cleaners, metal plating and chemical processing storage facilities, electrical/electronic manufacturing, and automobile repair and body shops. Wells south of the American River are considered vulnerable to leaking underground storage tanks and sewage collection systems. Copies of the complete assessments are available for review at the City of Sacramento Department of Utilities, 1395 35th Ave., or call 808-5454 to request a summary of the assessments.

TEAMWORK—TOGETHER WE CAN PROTECT OUR WATER RESOURCES

The City of Sacramento Department of Utilities works hard to bring you quality drinking water. Please be careful as you live, work and play to limit what goes into the storm drains and rivers, so we can continue to preserve the quality of the water and our diverse river ecosystem.



WATER IS OUR MOST PRECIOUS RESOURCE. USE IT WISELY.

HERE ARE SOME WAYS THAT YOU CAN HELP PRESERVE AND CONSERVE OUR WATER RESOURCES

FILL IT UP. Use your dishwasher and washing machine only for full loads.

GO GREEN. Purchase household and garden products that are "least toxic" to the environment.

LOOK FOR LEAKS. Inspect and maintain your car regularly to prevent leaks of oil, antifreeze and other fluids. Also, conserve water by fixing leaks around your home and yard.

APPLY WHEN DRY. Do not apply lawn or garden products when rain is forecasted and do not over-water your lawn.

PICK-UP AFTER YOURSELF AND YOUR PETS. Pick up your trash and put recycling in an appropriate bin. Shovel up animal wastes, seal it in bags and throw it away in a garbage can. Also, when visiting our rivers, be sure to use a public restroom or if your boat has a restroom, be sure to use a pumpout station to dispose of sewage safely.

SLOW THE FLOW. Use a low-flow hose nozzle when landscaping and only water on your assigned day. Also use a low-flow showerhead and take showers instead of baths.

SPEND TIME IN THE GUTTER. Keep the gutters clear of debris and lawn clipping to prevent clogging of storm drains. If you are putting out yard clippings for pick-up, sweep them into the street. Using a yard waste container can protect our local waterways by keeping yard waste out of the storm drain. Call 311 or (916) 264-5011 to request a container.

WATER QUALITY ANALYSIS RESULTS FOR 2010

The following table shows the detected contaminants in your drinking water and compares them with drinking water standards set by United States Environmental Protection Agency (USEPA) and the State Department of Public Health (Department). To request a complete report, including non-detected items, please call 311 or (916) 264-5011.

YOUR WATER MEETS OR EXCEEDS ALL CURRENT FEDERAL AND STATE REQUIREMENTS

DETECTED PRIMARY DRINKING WATER CONSTITUENTS REGULATED TO PROTECT YOUR HEALTH											
CONSTITUENT	UNITS	PHG OR (MCLG) OR [MRDLG]	MCL OR [MRDL]	SURFACE WATER			GROUND WATER			MAJOR SOURCES	
				RANGE	AVERAGE	YEAR OF SAMPLING	RANGE	AVERAGE	YEAR OF SAMPLING		
ARSENIC	PPB	0.004	10	ND-ND	ND	2006	ND-5.8	3.3	2008-2009	EROSION OR LEACHING OF NATURAL DEPOSITS	
BARIUM	PPM	2	1	ND-ND	ND	2006	ND-0.197	0.14	2008-2009	EROSION OR LEACHING OF NATURAL DEPOSITS	
CHROMIUM (TOTAL)	PPB	(100)	50	ND-ND	ND	2006	ND-16	ND	2008	EROSION OR LEACHING OF NATURAL DEPOSITS	
FLUORIDE (a)	PPM	1	2	0.17-1.11	0.83	2010	0.42-1.5	0.98	2010	WATER ADDITIVE THAT PROMOTES STRONG TEETH	
NITRATE (AS NITRATE)	PPM	45	45	ND	ND	2010	ND-20	6.46	2010	RUNOFF AND LEACHING FROM FERTILIZER USE; LEACHING FROM SEPTIC TANKS AND SEWAGE; EROSION OF NATURAL DEPOSITS	
DISTRIBUTION SYSTEM				RANGE	AVERAGE	YEAR OF SAMPLING	MAJOR SOURCES				
CHLORINE (DISTRIBUTION SYSTEM)	PPM	[4]	[4.0]	0.10-1.38			0.55			2010	DRINKING WATER DISINFECTANT ADDED FOR TREATMENT
TOTAL TRIHALOMETHANES (DISTRIBUTION SYSTEM)	PPB	N/A	80	ND-54			32.1			2010	BY-PRODUCT OF DRINKING WATER DISINFECTION
HALOACETIC ACIDS (DISTRIBUTION SYSTEM)	PPB	N/A	60	ND-46			21.5			2010	BY-PRODUCT OF DRINKING WATER DISINFECTION
CONTROL OF DISINFECTION BY PRODUCT PRECURSORS (TOC) (raw) (b)	PPM	N/A	TREATMENT REQUIREMENT OF AVERAGE TOC>2	1.1-2.0			1.47			2010	VARIOUS NATURAL AND MANMADE SOURCES
CONSTITUENT	UNITS	PHG OR (MCLG)	MCL OR [MRDL]	LEVEL FOUND			YEAR OF SAMPLING	MAJOR SOURCES			
TOTAL COLIFORM BACTERIA (TOTAL COLIFORM RULE)	% SAMPLES POSITIVE	(0)	MORE THAN 5.0% OF MONTHLY SAMPLES ARE POSITIVE	1.89%			2010	NATURALLY PRESENT IN THE ENVIRONMENT			
TURBIDITY (c), (d)	NTU	N/A	TT=1 NTU	0.44			2010	SOIL RUNOFF			
		N/A	TT=95% OF SAMPLES ≤0.3 NTU	99.6%							

DETECTED SECONDARY DRINKING WATER CONSTITUENTS REGULATED FOR AESTHETIC QUALITIES										
CONSTITUENT	UNITS	PHG OR (MCLG)	MCL	SURFACE WATER		YEAR OF SAMPLING	GROUND WATER		YEAR OF SAMPLING	MAJOR SOURCES
				RANGE	AVERAGE		RANGE	AVERAGE		
CHLORIDE	PPM	N/A	500	<5-10	5.7	2010	15-106	41	2008	EROSION OR LEACHING OF NATURAL DEPOSITS
COLOR	UNITS	N/A	15	1-1	1	2010	1-5	1	2008-2009	NATURALLY OCCURRING ORGANIC MATERIALS
SPECIFIC CONDUCTANCE	US/CM	N/A	1600	69-215	127	2010	270-720	440	2010	SUBSTANCES THAT FORM IONS WHEN IN WATER
SULFATE	PPM	N/A	500	5.9-25	12	2010	4.7-36	14	2008	EROSION OR LEACHING OF NATURAL DEPOSITS
TOTAL DISSOLVED SOLIDS (TDS)	PPM	N/A	1000	42-381	90	2010	207-613	238	2008-2009	EROSION OR LEACHING OF NATURAL DEPOSITS
TURBIDITY	NTU	N/A	5	0.03-0.18	0.07	2010	0.05-6.2	0.73	2008-2009	SOIL RUNOFF

DETECTED UNREGULATED DRINKING WATER CONSTITUENTS (e)										
CONSTITUENT	UNITS	PHG OR (MCLG)	MCL	SURFACE WATER		YEAR OF SAMPLING	GROUND WATER		YEAR OF SAMPLING	MAJOR SOURCES
				RANGE	AVERAGE		RANGE	AVERAGE		
HARDNESS	PPM	N/A	N/A	29-87	51.2	2010	116-332	190	2006-2007	HARDNESS IS THE SUM OF POLYVALENT CATIONS PRESENT IN THE WATER, GENERALLY NATURALLY OCCURRING MAGNESIUM AND CALCIUM
SODIUM	PPM	N/A	N/A	1.8-7.1	4.5	2006	19-39	28	2008	NATURALLY OCCURRING SALT IN THE WATER
CALCIUM	PPM	N/A	N/A	9.6-28	17.8	2010	30-110	55	2008	EROSION OR LEACHING OF NATURAL DEPOSITS
MAGNESIUM	PPM	N/A	N/A	1.4-5.4	3.4	2006	9.0-42	21	2008	EROSION OR LEACHING OF NATURAL DEPOSITS

(a) THE CITY'S FLUORIDATION PROGRAM PROVIDES THE ADDITION OF FLUORIDE TO ALL THE CITY'S DRINKING WATER. THE CITY ADJUSTS THE NATURAL LEVELS OF FLUORIDE IN OUR WATER SUPPLIES TO THE CALIFORNIA DPH RECOMMENDED OPTIMAL LEVEL.

(b) ONLY SURFACE WATER SOURCES MUST MONITOR FOR DBP PRECURSORS IN RAW WATER.

(c) ONLY SURFACE WATER SOURCES MUST COMPLY WITH PDWS FOR TURBIDITY.

(d) TURBIDITY IS A MEASURE OF THE CLOUDINESS OF THE WATER. WE MONITOR IT BECAUSE IT IS A GOOD INDICATOR OF THE EFFECTIVENESS OF OUR FILTRATION SYSTEM.

(e) UNREGULATED CONTAMINANT MONITORING HELPS DETERMINE WHERE CERTAIN CONTAMINANTS OCCUR AND WHETHER THEY NEED TO BE REGULATED.

THE STATE ALLOWS US TO MONITOR FOR SOME CONTAMINANTS LESS THAN ONCE PER YEAR BECAUSE THE CONCENTRATIONS OF THESE CONTAMINANTS DO NOT CHANGE FREQUENTLY. SOME OF OUR DATA, THOUGH REPRESENTATIVE, ARE MORE THAN A YEAR OLD.

WATER QUALITY TABLE ABBREVIATIONS

ND: Not detectable at reporting limit

NR: Not required

NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

PPB: Parts per billion or micrograms per liter

PPM: Parts per million or milligrams per liter

pCi/L: Picocuries per liter is a measure of radioactivity

µS/CM: Microsiemens per centimeter

IMPORTANT DEFINITIONS

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

WHAT YOU SHOULD KNOW ABOUT...

Arsenic: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Radon: Radon is a radioactive gas that you cannot see, taste or smell. Radon is found throughout the United States and can move up through the ground and into a home through cracks and holes in the foundation. Tap water may also release radon into the air in your home when showering, washing dishes or performing other household activities. Radon entering the home through tap water will, in most cases, be a small source of radon. Breathing air containing radon may lead to lung cancer and drinking water containing radon may cause increased risk of stomach cancer.

If you are concerned about radon in your home, testing is easy and inexpensive. There are simple, low cost ways to fix a radon problem, if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. Average radon levels in the City's groundwater supply between 1999 and 2000 ranged from 306 to 730 picocuries per liter, which is equal to less than 1 picocurie per liter in the air. For additional information, call the State Radon Program at (1-800-745-7236), the EPA Safe Drinking Water Act Hotline (1-800-426-4791), or the National Safe Council Radon Hotline (1-800-SOS-RADON).

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Sacramento Department of Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for cooking or drinking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The City of Sacramento Department of Utilities is dedicated to providing safe, reliable and environmentally sensitive water, drainage, sewer and flood control to our customers.

FOR MORE INFORMATION VISIT:
www.cityofsacramento.org/utilities

 www.facebook.com/SacramentoCityUtilities
 www.twitter.com/saccityutility